

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO. 5275-1194:100 Page 1 of 1

CATEGORY: Gas/Vapor Detectors

LISTEE: CCI Controls, 5052 Cecelia St., Southgate CA 90280
Contact: Bob Flegal (213) 560-6060

DESIGN: Models 7724 and 7730 LPG detector with controller. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, operating instructions and National Consumer Testing Institute label (US Testing Co Inc).

APPROVAL: Listed as a gas/vapor detector.

NOTE: Not a substitute for any listed smoke detector. Not suitable for installations in hazardous areas.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 12, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO, Supervising Deputy
Program Manager**